Fire Protection Code Checklist

Are you READY?

The National Fire Protection Association (NFPA) is an international non-profit organization that develops and publishes minimum fire protection codes and standards.





Fire Extinguishers	Required Frequency	NFPA Code
Inspections	All Types Monthly	NFPA 10
Maintenance & Certification	All Types Annually	NFPA 10
Internal Exam: Foam	3 Years	NFPA 10
Hydro Test: CO2, Wet Chemical, Foam &	5 Years	NFPA 10
Water	5 Years	NFPA 10
Internal Exam: Dry Chemical, Halo Agents	6 Years	NFPA 10
Hydro Test: Dry Chemical, Halo Agents	12 Years	NFPA 10



Fire Alarms	Required Frequency	NFPA Code
Supervisory Devices	Semi-Annual	NFPA 72
Battery Load Testing	Semi-Annual	NFPA 72
Controls, Panels, Power Supply, Annunciators	Annual	NFPA 72
Initiating Devices	Annual	NFPA 72
Notification Appliances	Annual	NFPA 72
Smoke Detector Sensitivity Testing	1-yr after install, then every 2 yrs	NFPA 72



Fire Sprinklers	Required Frequency	NFPA Code
Inspections	Quarterly, Annual, Semi-Annual	NFPA 25
Standpipe System Inspection	Semi-Annual	NFPA 25
Backflow Testing	Annual	NFPA 25
Fire Pumps & Fire Hydrants Service	Annual	NFPA 25
Dry System Full Trip	3 Years	NFPA 25
Internal Inspection	5 Years	NFPA 25
Standpipe Systems Service & Certification	5 Years	NFPA 25
Fire Department Connection Hydro Test Installation	5 Years	NFPA 13



Emergency & Exit Lighting	Required Frequency	NFPA Code
Functional Test - 30 seconds	Monthly	NFPA 101
Functional Test - 90 minutes	Annual	NFPA 101



Fire Suppression	Required Frequency	NFPA Code
Kitchen Wet Checmical System Inspections	Semi-Annual/Annual	NFPA 17A
Clean Agent Fire Suppression Inspections	Semi-Annual/Annual	NFPA 2001
CO2 System Inspections	Semi-Annual/Annual	NFPA 12
Halon 1301 System Inspections	Semi-Annual/Annual	NFPA 12A
Dry Chemical System Inspections	Semi-Annual/Annual	NFPA 17
Hydro Test Kitchen Systems	12 Years	NFPA 17 I NFPA 17A



If you're ready to experience the most dependable and simplified life safety solution on the planet, let's talk.



